



OFFICE OF THE EXECUTIVE ENGINEER ELECTRICAL, BMC

Quotation call notice No. 04/ dtd. 13.07.2026

File No- XXVII- 256/2022

Letter No 41579 / BMC Dt. 13-7-26

Sealed quotations are invited on plain paper or the bidder's printed letterhead from registered authorized dealers for the work mentioned below.

The sealed quotations shall be received up to **04:00 P.M. on 27.07.2026** and will be opened at **11:00 A.M. on 28.07.2026** in the presence of the quotationers or their authorized representatives who wish to attend. The authority reserves the right to reject any or all quotations without assigning any reason thereof.

Sl No	Description of Items	Unit	Rate without GST
1	SITC of Hybrid (Solar + Windmill) LED Street lighting system with minimum following technical specifications: 1. Solar Panel (400 Wp to 600 Wp, Monocrystalline PV panel) (MNRE/ IEC/ NABL approved) 2. Windmill (UV resistant HDPE/ PPE body, IP 53 enclosure, rated output 45 W@11 m/s to 150 W@17 m/s, CE certified and IEC 61400-2 certified by NIWE 3. Luminaire (60 Watt $\pm$ 5 %, $\geq$ 140 lm/W) (> 50,000 hours life span) 4. Maintenance Free Battery (BIS Approved) 60 Ah LiFePO4 with Backup time > 1.5 days (Weather resistance IP 65) 5. Pole structure (Octagonal Pole 6 Mtr Height) with Wind withstanding capacity $\geq$ 120 Kmph, Hot Dip GI (100 micron), Top dia: 70 mm, Bottom dia: 120-150 mm, Thickness: 3 mm with all other accessories 6. Single Arm Bracket (1 Mtr.) & Double Arm Bracket (double battery) (1 Mtr.) 7. Foundation	1 Set	

For any queries, please contact

Contact Details: 7205611993, 6371739692

By Order of Commissioner, BMC

V. Pandey
13/07/26

Executive Engineer (Electrical)
Bhubaneswar Municipal Corporation